

Procurement Office
Harford Community College
401 Thomas Run Road
Bel Air Maryland 21015
443.412.2307

IFB 17B-001 BELCAMP CENTER BUILDING RENOVATIONS

ADDENDUM NO. 1

The following shall be incorporated into the captioned solicitation as though included in the original documents issued:

Page 1 paragraph 8, 2nd sentence Change to Read: Award is anticipated to be made after March 14, 2017.

Questions/Answers

- Q1: What is the framing type on the block walls in BC-7? It will have to be deep enough for electrical boxes unless we surface mount the boxes.
A1: 1-1/2 inch hat channel. Wire mold will be installed under counter.
- Q2: We are assuming the ceiling is plenum. The existing return grilles are in the ceiling grid without ductwork.
A2: Correct
- Q3: What is the spec on the replacement lamps for the existing lights?
A3: To match existing
- Q4: Is there a ceiling tile replacement quantity?
A4: All damaged tile to be replaced no matter cause.
- Q5: The fume hood exhaust duct goes through the exterior wall and up an outside chase. Can the duct be terminated at the wall?
A5: Demolition notes define this work
- Q6: Is there any concern about what fumes may be have been exhausted through the ductwork or the green PVC piping?
A6: No caustic or hazardous material was ever used in this building.
- Q7: For the telecommunication cabling, is there a specific brand and color?
A7: No specific brand, blue for data, grey for voice. All cables shall be Cat 6 IEEE certified.
- Q8: Is there a specific brand and color for the data jacks and faceplates?
A8: Leviton or equal. Jack color to match cable, faceplates to match existing in building.

Q9: The current jacks and faceplates that will remain intact during renovations-will it be ok to replace the existing jacks and faceplates with the new color jacks and faceplates so everything is uniform?

A9: Yes

Q10: Will it be ok if we replace the current patch panel in the telecom room with a new patch panel and dress up the current telecom room to standard?

A10: Patch Panel shall be replaced.

Q11: Will the door frames be painted the same color as the walls?

A11: Yes

Q12: What is the weight of the new ballistic rated sliding window we will be installing?

A12: 250 pounds

Q13: Will we be required to pull permits?

A13: Yes

Q14: Would you consider changing the ballasts to support the new LED bulbs in all the lights?

A14: No; specifications call for new LED bulbs only in all lay-in fixtures.

Q15: Are we to remove the photocell for the light at the front entrance when the light is replaced? Is that light on its own switch?

A15: Yes replace the photo-eye. The light shall not be on a switch.

END ADDENDUM 1

February 7, 2017