

Procurement Office
Harford Community College
401 Thomas Run Road
Bel Air Maryland 21015
443.412.2307

IFB 17B-004 PARKING LOT #3 REPAIRS

ADDENDUM NO. 1

The following shall be incorporated into the captioned solicitation as though included in the original documents issued:

ADD the following:

- 8.1.9. Handicap Parking Area
- .1 Remove existing concrete sidewalk directly in front of handicap parking area.
 - .2 Replace in-kind at proper elevation and slope to meet ADA requirements.
 - a. The existing sidewalk does not meet ADA slope requirements.
 - .3 Concrete gutter shall be placed between the walk and asphalt parking lot.

Questions/Answers

- Q1: It was talked about using 8 inch face curb on one side of the parking lot and 6 inch face curb on the other side. Could we use all 6 inch curb and gutter and just transition it to the existing 8 inch curb as needed?
A1: 6 inch curb will be used at all locations
- Q2: Will we need to place Warning Domes at the HC spaces when we replace the sidewalk in that area? If so, what size will we have to make them? The whole area or just in front of the hashed areas?
A2: Hashed areas only
- Q3: Will the testing be on us or is the College going to have someone onsite?
A3: The College will handle testing
- Q4: Is the item to replace 750 SF of sub-base part of the Lump Sum price or is it paid under the unit prices 2.1 and 2.2?
A4: Part of the Lump Sum
- Q5: What is the thickness of the existing asphalt walk to be removed?
A5: Five inches
- Q6: Does removal of the walk include the stone sub base or may the stone sub base be re-used?
A6: Can be reused
- Q7: Please provide a detail for the concrete curb and sidewalk.
A7: Refer to specifications 8.1.3

Q8: Please provide a detail for the asphalt parking lot tie in to the new curb.
A8: Will be coordinated in field, no detail will be provided

Q9: Is new line striping required?
A9: Yes, entire parking lot

Q10: Will the parking lot be closed during construction? If not, please delineate portion of parking lot to remain open.
A10: Yes, lot will be closed

END ADDENDUM 1

March 3, 2017