

Procurement Office
Harford Community College
401 Thomas Run Road
Bel Air Maryland 21015
443.412.2307

IFB 19B-003 PARKING LOT A IMPROVEMENTS AND NORTHERN TRAIL EXTENSION

ADDENDUM NO. 1

The following shall be incorporated into the captioned solicitation as though included in the original documents issued:

Questions/Answers

Q1: Is there a budget for the Parking Lot "A" Improvements and Northern Trail Extension project?

A1: Information not available.

Q2: Can millings be used for the stone base on the new Pull Off Area?

A2: No, compacted CR6 shall be used as a stone base.

Q3: Please confirm that we are not to place the Concrete ramps or crosswalk on Thomas Run Road.

A3: Confirmed

Q4: On the three concrete ramps we are doing, the one on the right of roadway does not show detectable warning surface? Are we to install them on all three?

A4: Yes

Q5: Does the new curb and gutter that will be installed behind Bel Air Hall get painted red?

A5: Yes

FYI:

The College was contacted by ProStripes.com regarding providing pricing for pavement markings to Contractors bidding this project. Contact information: DJ Kirby- email: DJ@prostripes.com; telephone: 443-254-7322

END ADDENDUM 1

May 14, 2019