

Procurement Office  
Harford Community College  
401 Thomas Run Road  
Bel Air Maryland 21015  
443.412.2307

**IFB 19B-003 PARKING LOT A IMPROVEMENTS AND NORTHERN TRAIL EXTENSION**

ADDENDUM NO. 2

The following shall be incorporated into the captioned solicitation as though included in the original documents issued:

1. Scope of Work and Specifications paragraph 8.1.3 Curb and Gutter Replacement **CHANGE TO READ:**
  - .2 Saw cut, remove and replace **24"** of adjacent asphalt for all curb and gutter replacements. This will allow for better compaction of the asphalt.

Questions/Answers

Q1: Is there a budget for the Parking Lot "A" Improvements and Northern Trail Extension project?  
A1: Information not available.

Q2: Can millings be used for the stone base on the new Pull Off Area?  
A2: No, compacted CR6 shall be used as a stone base.

Q3: Please confirm that we are not to place the Concrete ramps or crosswalk on Thomas Run Road.  
A3: Confirmed

Q4: On the three concrete ramps we are doing, the one on the right of roadway does not show detectable warning surface? Are we to install them on all three?  
A4: Yes

Q5: Does the new curb and gutter that will be installed behind Bel Air Hall get painted red?  
A5: Yes

FYI:  
The College was contacted by ProStripes.com regarding providing pricing for pavement markings to Contractors bidding this project. Contact information: DJ Kirby- email: [DJ@prostripes.com](mailto:DJ@prostripes.com); telephone: 443-254-7322

**END ADDENDUM 2**

May 17, 2019